



## LM-79-08 Test Report

for

**P.Q.L., Inc.**

2285 Ward Avenue / Simi Valley, CA 93065

**T8 LED Replace lamp**

**Model: 9087X, 90875**

**Laboratory: Leading Testing Laboratories**

**NVLAP CODE: 200960-0**

No.1805, DongLiu road, BinJiang District, Hangzhou, China

Tel: +86-571-56680806

www.ledtestlab.com

Report No.: HZ16010020c

The laboratory that conducted the testing detailed in this report has been accredited for SSL by NVLAP.

Review by:

Engineer: April Zou  
Feb. 01, 2016

Approved by:



Manager: Jim Zhang  
Feb. 01, 2016

Note: This report does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government

## Test Summary

<b>Model</b>	<b>9087X, 90785</b>
<b>Luminous Efficacy (Lumens /Watt)</b>	102.1
<b>Total Luminous Flux (Lumens)</b>	1901.0
<b>Power (Watts)</b>	18.62
<b>Power Factor</b>	0.9963
<b>CCT (K)</b>	2966
<b>CRI</b>	82.8
<b>Stabilization Time (Light &amp; Power)</b>	60 mins
<b>Note</b>	3000K, Frosted Lens

Table 1: Executive Data Summary

### Test specifications:

<b>Date of Receipt</b>	: Jan. 15, 2016
<b>Date of Test</b>	: Jan. 20, 2016
<b>Test item</b>	: Total Luminous Flux, Luminous Efficacy, Correlated Color Temperature, Color Rendering Index, Chromaticity Coordinate, Electrical parameters
<b>Reference Standard</b>	: IESNA LM-79-2008 Approved Method for the Electrical and Photometric Measurements of Solid-State Lighting Products

## TABLE OF CONTENT

LM-79-08 Test Report.....	1
Test Summary.....	2
Sample Photos .....	4
TEST RESULTS .....	5
Spectral Power Distribution - Sphere Spectroradiometer Method .....	6
Chromaticity Diagram - Sphere Spectroradiometer Method.....	7
Nominal CCT Quadrangles – Sphere Spectroradiometer Method .....	8
EQUIPMENT LIST .....	9
TEST METHODS .....	9
Seasoning of SSL Product.....	9
Sphere-Spectroradiometer Method- Photometric and Electrical Measurements.....	9

### Sample Photos



Sample view

#### Equipment Under Test (EUT)

<b>Name</b>	: T8 LED Replace lamp
<b>Model</b>	: 9087X, 90875
<b>Electrical Ratings</b>	: 100-277VAC, 50/60Hz
<b>Product Description</b>	: 3000K, frosted Lens, G13 base, fixed ends caps, No dimmable Manufacturer of light source: Lextar Model of LED light source: PC35H11.V0 LED Tubes supplied by a high frequency fluorescent lamp ballast: SYLVANIA QTP 1x32T8/UNV ISN-SC
<b>Manufacturer</b>	: P.Q.L., Inc.
<b>Address</b>	: 2285 Ward Avenue / Simi Valley, CA 93065

## TEST RESULTS

Test ambient temperature was 24.9°C.

Test orientation was Horizontal. Test was conducted without a dimmer in the circuit.

The stabilization time of the sample was 60 minutes, and the total operating time including stabilization was 65 minutes.

Parameter	Result	
	Test Voltage (V)	120.0
Voltage frequency (Hz)	60	60
Test Current (A)	0.156	0.070
Power Factor	0.9963	0.9697
Test Power (W)	18.62	18.84
THD A%	6.54	13.14
Luminous Efficacy (lm/W)	102.1	101.0
Total Luminous Flux (lm)	1901.0	1902.0
Color Rendering Index (CRI)	82.8	
R9	14.2	
Correlated Color Temperature (CCT)(K)	2966	
Chromaticity Chroma x	0.4377	
Chromaticity Chroma y	0.4018	
Chromaticity Chroma u	0.2521	
Chromaticity Chroma v	0.3471	
Duv	0.0012	
Chromaticity Chroma u'	0.2521	
Chromaticity Chroma v'	0.5206	

Special Color Rendering Indices	
R1	81.3
R2	89.9
R3	96.3
R4	81
R5	80.9
R6	86.9
R7	84.2
R8	62.3
R9	14.2
R10	76.4
R11	79.6
R12	69.7
R13	83.1
R14	98

Table 2: Test data per Sphere-Spectroradiometer Method

Note: According to CIE 1976 (u',v') diagram,  $u' = u = 4x/(-2x+12y+3)$ ,  $v' = 3v/2 = 9y/(-2x+12y+3)$ .

### Spectral Power Distribution - Sphere Spectroradiometer Method




Chart 1: Spectral Power Distribution

Spectral Distribution over Visible Wavelength							
WL(nm)	Radiant(Watts)	WL(nm)	Radiant(Watts)	WL(nm)	Radiant(Watts)	WL(nm)	Radiant(Watts)
380	2.15E-04	485	6.62E-03	590	3.63E-02	695	8.72E-03
385	2.06E-04	490	7.70E-03	595	3.73E-02	700	7.59E-03
390	2.22E-04	495	9.29E-03	600	3.79E-02	705	6.60E-03
395	2.45E-04	500	1.12E-02	605	3.82E-02	710	5.69E-03
400	2.96E-04	505	1.32E-02	610	3.80E-02	715	4.95E-03
405	3.55E-04	510	1.49E-02	615	3.74E-02	720	4.28E-03
410	5.22E-04	515	1.64E-02	620	3.62E-02	725	3.68E-03
415	8.69E-04	520	1.75E-02	625	3.49E-02	730	3.17E-03
420	1.55E-03	525	1.87E-02	630	3.31E-02	735	2.72E-03
425	2.67E-03	530	1.97E-02	635	3.12E-02	740	2.35E-03
430	4.30E-03	535	2.07E-02	640	2.92E-02	745	2.00E-03
435	6.64E-03	540	2.19E-02	645	2.70E-02	750	1.72E-03
440	1.05E-02	545	2.30E-02	650	2.48E-02	755	1.48E-03
445	1.69E-02	550	2.41E-02	655	2.26E-02	760	1.28E-03
450	2.08E-02	555	2.55E-02	660	2.04E-02	765	1.10E-03
455	1.74E-02	560	2.70E-02	665	1.84E-02	770	9.37E-04
460	1.26E-02	565	2.86E-02	670	1.64E-02	775	8.06E-04
465	1.02E-02	570	3.02E-02	675	1.46E-02	780	6.89E-04
470	8.15E-03	575	3.19E-02	680	1.29E-02		
475	6.58E-03	580	3.35E-02	685	1.14E-02		
480	6.26E-03	585	3.50E-02	690	9.99E-03		

Table 3: Spectral Power Distribution Numerical Data per Sphere - Spectroradiometer Method

### Chromaticity Diagram - Sphere Spectroradiometer Method




Chart 2: Chromaticity Diagram per Sphere - Spectroradiometer Method

Note: The location on the diagram of the tristimulus coordinates are indicated by the blue diamond.

**Nominal CCT Quadrangles – Sphere Spectroradiometer Method**




Chart 3: Plot of Lamp x/y coordinates on CIE 1931 Chromaticity Diagram



## EQUIPMENT LIST

Test Equipment	Model	Equipment No.	Calibration Date	Calibration Due date
Integrate Sphere system	2M	HZTE015-01	Jul. 16, 2015	Jul. 15, 2016
Digital Power Meter	WT210	HZTE008-01	Jul. 17, 2015	Jul. 16, 2016
AC Power Supply	PCR 500L	HZTE001-07	Jul. 17, 2015	Jul. 16, 2016
DC Power Supply	6154	HZTE004-04	Jul. 17, 2015	Jul. 16, 2016
Temperature and humidity recorder	JR900	HZTE018-01	Jul. 21, 2015	Jul. 20, 2016
Standard source	SCL-1400	HZTE012-02	Oct. 21, 2015	Oct. 20, 2016

Table 4: Test Equipment List

## TEST METHODS

### Seasoning of SSL Product

For the purpose of rating new SSL products, SSL products shall be tested with no seasoning. Therefore, no seasoning was performed.

### Sphere-Spectroradiometer Method- Photometric and Electrical Measurements

A Labsphere Model CDS 2100 Spectroradiometer and Two Meter Sphere was used to measure correlated color temperature, chromaticity coordinates, and the color rendering index for each SSL unit. The coating reflectance of each sphere is 98%. The measure geometry is  $4\pi$ . Self-absorption correction is conducted in testing. Bandwidth of spectroradiometer is 350nm-1050nm.

Ambient temperature was measured at a position inside the sphere. Each SSL unit was operated on the client provided driver at the rated input voltage in its designated orientation.

The stabilization time typically ranges from 30 min (small integrated LED lamps) to 2 or more hours for large SSL luminaires). It can be judged that stability is reached when the variation (maximum – minimum) of at least 3 readings of the light output and electrical power over a period of 30 min, taken 15 minutes apart, is less than 0.5 %.

Electrical measurements including voltage, current, and power were measured using the Yokogawa Power Analyzer.

The standard reference of the integrated sphere system is halogen incandescent lamp, the intensity distribution type is omni-directional, and is traceable to the National Institute of Standards and Technology.

The uncertainty of integrating sphere system reported in this document is expanded uncertainty is 1.06% with a coverage factor  $k=2$ .

\*\*\* End of Report \*\*\*

This report is considered invalidated without the Special Seal for Inspection of the LTL. This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of LTL, this test report shall not be copied except in full and published as advertisement.